

# RGS Instrument and Calibration Status

**XMM-Newton Users' Group Meeting #25**

**ESAC, June 26-27 2024**

Rosario González-Riestra

XMM-Newton Science Operations Centre

on behalf of the SRON and XMM-SOC RGS Teams

---

---


# Outline



- Operations and Instrument Status
  - System Peak
  - Charge Transfer Efficiency
  - Bad Surface
  - Hot spots and hot columns
- Calibration and Monitoring
  - Wavelength Scale
  - Effective Area
  - Flux monitoring

# Operations

- Operations running without problems
- Same operational configuration
- No instrumental anomalies
- No degradation of the instrumental parameters, except for a steeper decrease in CTE




**STABLE** → NO NEED FOR CCF UPDATE





Monitoring from internal calibration sources

Calibration is done through dedicated observations of Mkn 421, off-axis for the parallel CTI, on-axis for the serial CTI





from J. dePlaa presentation  
2024 RGS Calibration Meeting

CCF UPDATED MARCH 2024


Release Note: CAL-SRN-405

# Instrument Status: Bad Surface



2%


STABLE



**STABLE** → NO NEED FOR CCF UPDATE

*RGS Diagnostic Trend Analysis Reports*





Columns *rejected on-board*

- 1 in RGS1 CCD 1
- 1 in RGS2 CCD 9

Columns flagged as *advisory* in CCF


- 6 in RGS1 (3 in CCD6 + 2 in CCD4 + 1 in CCD1)
- 6 in RGS2 (2 in CCD3 + 4 in CCD 1)

**STABLE** → NO NEED FOR CCF UPDATE


*RGS Diagnostic Trend Analysis Reports*

# Instrument Status: Hot Columns

Columns found hot in more than 25% of the observations




Columns found hot in more than 95% of the observations



*RGS Diagnostic Trend Analysis Reports*

# Wavelength Scale



Wavelength shift of spectra of bright emission-line stars

Shift of individual lines (median $\pm \sigma$ )	
RGS 1	RGS 2
1 <sup>st</sup> order	
$-2 \pm 5$ mÅ [335 lines]	$-3 \pm 5$ mÅ [348 lines]
2 <sup>nd</sup> order	
$-2 \pm 5$ mÅ [206 lines]	$-3 \pm 5$ mÅ [259 lines]

**STABLE**

Small scale Effective Area correction applied **by default**, with rgsproc/rgsrmfgen parameter **witheffectiveareacorrection=yes**

**CCF UPDATED APRIL 2023**

Correction with respect to EPIC-pn (aka Rectification) applied with rgsproc/rgsrmfgen non-default option **withrectification=yes**


**CCF UPDATED SEPTEMBER 2023**

Effective Area and Rectification Corrections haven been applied in the Bulk Reprocessing. This will be the default in SASv22

**rgsproc/rgsrmfgen witheffectiveareacorrection=yes  
withrectification=yes**

Re-derived in September 2023 following the update of the Effective Area correction in April 2023


*Release Note: CAL-SRN-401*



Since 2015, extra contamination present, not consistent with Hydrocarbons.

New contaminant unknown (could be Related to Hydrazine?)




Empirically corrected through the "Rectification Correction"



# Rectification Correction

Application to a sample of BL Lacs (consistency check)




## RGS/EPIC-pn Flux Ratio



# Rectification Correction

## Application to the ISN RXJ1856-3754

### RGS/EPIC-pn Flux Ratio







# Flux Monitoring: RXJ1856-3754

Flux from fit to an absorbed Blackbody with fixed column density


15Å



25Å



35Å



Flux ( $10^{-4}$  ph/cm<sup>2</sup>/s/Å)

RGS1 0.10 +/- 0.01  
RGS2 0.10 +/- 0.01


RGS1 2.7 +/- 0.2  
RGS2 2.7 +/- 0.2

RGS1 6.6 +/- 0.6  
RGS2 6.7 +/- 0.6


# Flux Monitoring: RXJ1856-3754

Flux from fit to an absorbed Blackbody with fixed column density


15Å



25Å



35Å




Flux ( $10^{-4}$  ph/cm<sup>2</sup>/s/Å)

RGS1	0.10 +/- 0.01	0.11 +/- 0.01
RGS2	0.10 +/- 0.01	0.11 +/- 0.01

RGS1	2.7 +/- 0.2	2.7 +/- 0.1
RGS2	2.7 +/- 0.2	2.7 +/- 0.1


RGS1	6.6 +/- 0.6	6.6 +/- 0.2
RGS2	6.7 +/- 0.6	6.6 +/- 0.2

# Flux Monitoring: RXJ1856-3754



eV


RGS1	61.7 +/- 0.8
RGS2	61.7 +/- 0.8



$10^{-4}$  photons/cm<sup>2</sup>/s/Å


RGS1	3.1 +/- 0.3
RGS2	3.2 +/- 0.4

# Flux Monitoring: RXJ1856-3754



eV

RGS1	61.7 +/- 0.8	62.2 +/- 0.6
RGS2	61.7 +/- 0.8	62.2 +/- 0.7




$10^{-4}$  photons/cm<sup>2</sup>/s/Å

RGS1	3.1 +/- 0.3	3.1 +/- 0.1
RGS2	3.2 +/- 0.4	3.1 +/- 0.1


# Flux Monitoring: Vela Pulsar

Flux from fit to an absorbed Powerlaw with fixed column density


15Å



25Å



35Å



Flux ( $10^{-3}$  ph/cm<sup>2</sup>/s/Å)

RGS1 0.99 +/- 0.04  
RGS2 0.98 +/- 0.04


RGS1 1.10 +/- 0.07  
RGS2 1.12 +/- 0.08

RGS1 0.95 +/- 0.08  
RGS2 0.98 +/- 0.09


# Flux Monitoring: Vela Pulsar

Flux from fit to an absorbed Powerlaw with fixed column density


15Å



25Å



35Å




Flux ( $10^{-3}$  ph/cm<sup>2</sup>/s/Å)

RGS1	0.99 +/- 0.04	1.02 +/- 0.02
RGS2	0.98 +/- 0.04	1.00 +/- 0.03


RGS1	1.10 +/- 0.07	1.13 +/- 0.02
RGS2	1.12 +/- 0.08	1.14 +/- 0.02

RGS1	0.95 +/- 0.08	0.97 +/- 0.02
RGS2	0.98 +/- 0.09	0.99 +/- 0.02

# Flux Monitoring: Vela Pulsar




RGS1      2.39 +/- 0.07  
 RGS2      2.44 +/- 0.08




$10^{-2}$  photons/cm<sup>2</sup>/s/Å

RGS1      1.25 +/- 0.04  
 RGS2      1.24 +/- 0.04

# Flux Monitoring: Vela Pulsar



RGS1	2.39 +/- 0.07	2.37 +/- 0.03
RGS2	2.44 +/- 0.08	2.42 +/- 0.03



$10^{-2}$  photons/cm<sup>2</sup>/s/Å

RGS1	1.25 +/- 0.04	1.30 +/- 0.04
RGS2	1.24 +/- 0.04	1.26 +/- 0.04



# Summary

## Operations and Instrument Status

- Operations running smoothly
- No unexpected behaviour in the instrumental performance, except for a steeper decrease in CTE -> **CCF UPDATED**
- No changes in hot columns / hot spots -> **NO CCF UPDATE NEEDED**

## Wavelength scale

- Wavelength scale stable
- No significant trend with time
- No degradation in spectral resolution

## Effective Area

- Variations in Effective Area continuously monitored
- Empirical corrections to take into account the observed change in Effective Area in place
  - Effective area correction -> **CCF UPDATED**
  - Rectification correction -> **CCF UPDATED**